



When we have CFMF and Masonry, we must make sure that we coordinate the masonry requirements per building code MSJC 530.1 with the CFMF shop drawings in order not to forget about important stud placement requirements, prior to the sheathing and/or air barrier installation:



Stud Requirements / Stud Additions Needed

- We must use minimum 18ga, G90 material.
- The design guideline is L/600 minimum.
- Minimum fastener size is #10 hot dipped, coated, or stainless steel.
- Corrugated wall ties and 9ga wire does not meet code.
- Stud with-in 3"-12" of inside or outside corner.
- Stud with-in 3"-12" of window or door opening.
- Studs NOT closer than 3" for an anchor @ opening.
- Stud with-in 3"-12" of either side of Masonry MJ.

