



The wood coping roof nailer supports the air/vapor barrier and the roofing, as well as structurally support the metal coping. These membranes must be fully supported...Gaps in wood are not acceptable.



*Review the specifications for a minimum wood width, typically a 2"x6"*



Also make sure that we use wood with no large or loose knots, as these are unacceptable defects in the wood which could dislodge over time.