



The HVAC curb is typically galvanized metal with treated wood blocking on the top edge using interior fasteners...



Treated wood blocking requires an ice and water shield separation between the wood and the frame and the use of exterior coated or stainless steel fasteners.

The HVAC contractor needs to discuss this concern with the fabricator prior to the order of the curbs in order to prevent the added cost to correct the issues in the field.

Please talk to your subcontractor...