


Fire-rated doors require Steel Shims Only



Section 6.4.3.4 Shimming

“When required to meet the clearances, shimming of hinges shall be permitted using steel shims.”

It is NOT acceptable to use cardboard, wood strips, or plastic shims when shimming any fire-rated door assemblies.

